



**NATIONAL INSTITUTE OF TECHNOLOGY  
TIRUCHIRAPPALLI-620 015  
ESTATE MAINTENANCE DEPARTMENT**

NITT/EMD/ EE/AMC/STP/Tender/2019-20/001

15.07.2019

**MINUTES RECORDED AT THE PREBID MEETING FOR Operation & Maintenance  
of Sewage treatment plants capacity of 300 KLD & 800 KLD at NITT campus,  
Tiruchirappalli**

Sl No	Point for discussed in the meeting	Responses by EMD
01	In Page no 6, “At least 3 years’ experience in maintenance of municipal wastewater treatment system...”.	It may read as ““At least 3 years’ experience in maintenance of municipal/domestic wastewater treatment system...”
02	Page 12, Point 11 “Removal of dried sludge from sludge drying bed..... and filled with river sand...”.	Use M’sand for alternative to river sand can be permitted, provided, if the M-sand fulfill the required parameter. The parameter fulfillment will be tested in the NITT laboratory.
03	Page 12, Treated Sewage Characteristics Required	Use Ministry of Environment Amendment rules, 2017. In place of Environmental Rules 1986
04	Page 33, Point 6 <sup>th</sup> and 10 <sup>th</sup> Periodically clean and service every six months.	Not necessary every six months but yearly once compulsory clean and service.
05	Page 33, Point 9 <sup>th</sup> , 11 <sup>th</sup> are discussed	Follow the 9 <sup>th</sup> and 11 <sup>th</sup> point actual as it is.



**NATIONAL INSTITUTE OF TECHNOLOGY  
TIRUCHIRAPPALLI-620 015  
ESTATE MAINTENANCE DEPARTMENT**

06	Page 38 and 39, discussed Period of contract.	Initially the contract will be awarded for 3 months. On satisfactory performance and test results. The contract will be extended for further 9 months. At the end of 12 months, based on satisfactory performance the contract may extend to another 12 months, (ie 2 <sup>nd</sup> year)
07	Page 39, discussed about bonus mention ' f ' Point.	Bonus should be given every month along with salary.
Point BY NITT:		
16	The estimate value (1 <sup>st</sup> page) calculated presumed the GST of 5% of estimate value. However actual GST will be paid on production of proof.	